



Inspections Bulletin

Subject:

**Supplementary Grounding
Electrodes**

Bulletin Number:

2008-01

Effective Date: 11/1/2007	Code: 2005 Nat. Electrical Code	Section: 250.56	Page: 70-103
-------------------------------------	---	---------------------------	------------------------

After an extensive study and review, the Town of Wake Forest Code Enforcement Officials will start strictly enforcing the Section 250.56 of the 2005 Edition of the National Electrical Code. This section addresses the 25 ohms or less requirement for Supplementary Grounding Electrodes.

If the electrical contractor verifies that a single electrode does meet the 25 ohms or less requirement, then the electrical contractor will be required to document these results in an official letter to the Code Official. The Town of Wake Forest Code Official will reserve the right to witness the test of the system.

This document shall include, but not be limited to, the following information:

- General Contractors name and license number (if applies)
- Electrical Contractors name and license number
- Address of system being tested
- Method of test
- Test results
- Sign and print name of person performing the test
- Sign and print name of Electrical Company license holder

Prepared By:

DP

Approved By:

JJC